



Petition #:	2019-177	Review Number:	1
Petition Respondent:	Bhavana Swayampakala	Date Reviewed:	1/22/2020
Phone Number:	704-336-4976	Email Address:	bhavana.swayampakala@charlottenc.gov

Comments:

Summary: Water and sewer service is accessible for this rezoning boundary.

Charlotte Water has accessible water system infrastructure for the rezoning boundary via an existing 16-inch water transmission main located along Ridge Road.

Charlotte Water has accessible sanitary sewer system infrastructure for the rezoning boundary via an existing 8-inch gravity sewer main located along Forestridge Commons Drive.

Development is encouraged to contact Installation Development Services at (704) 336-5499 to review service connection design requirements and City Ordinances (e.g., backflow, separate meter Ordinance, public/private pipeline extensions). Comments: Has direct access to sewer. Has direct access to water. Will need to acquire CAP for meters 1.5" and larger. Contact CLT Water New Services Department for water/sewer services. Contact CLT Private Water for private water systems. Contact CLT Water Donated Projects to extend public infrastructure along proposed public R/W. If Old Ridge Road R/W is abandoned, the existing 16" water line will need to be relocated.

Reservation of sanitary sewer system capacity through the Charlotte Water's Capacity Assurance Program is the responsibility of the customer/development. Contact the New Services Group at (704) 432-2854 for further information on reserving capacity up to 24 months.

This sheet indicates the findings of a cursory review of Utilities System Information for the presence or absence of public water or wastewater infrastructure only. The findings do not imply available capacity in water and sanitary sewer lines, pump stations, or treatment facilities. Reservation of capacity is achieved through the Charlotte Water's Capacity Assurance Program.