



Charlotte Storm Water
600 East Fourth Street
Charlotte, N C 28202-2844

Rezoning Petition Review

To: Charlotte Planning, Design & Development

From: Doug Lozner

Date of Review: January 17, 2020

Rezoning Petition #: 19-184

Existing Zoning: R-3

Proposed Zoning: R-17MF (CD)

Location of Property: Approximately 4.2 acres located on the north side of West WT Harris Blvd and west of I-485

Site Plan Submitted: Yes

Recommendations

Concerning Storm Water: City of Charlotte GIS data indicates a 30-ft PCSO buffer across the site. Please show and label *Potential 30-ft PCSO Buffer* on the site plan. Any increase of impervious area within such buffers may not be allowed and is not approved with the rezoning process. Stream Delineation Reports are subject to review and approval by Charlotte Storm Water Services. Please include the following note under Environmental Features: *"Development within any SWIM/PCSO Buffer shall be coordinated with and subject to approval by Charlotte-Mecklenburg Storm Water Services and mitigated if required by City ordinance. Petitioner acknowledges intermittent/perennial stream delineation reports are subject to review and approval upon submission of development plans for permitting and are not approved with rezoning decisions."*

Please include the following note under Environmental Features. *The petitioner shall analyze the adequacy of the existing storm water conveyance to the nearest public right-of-way. If the existing storm water conveyance is are found to be inadequate, the Petitioner shall make a good faith effort to improve the storm water conveyance or mitigate the storm water discharge.*